

ORDINANCE 2006-01

**AN ORDINANCE OF THE BOARD OF DIRECTORS OF THE MCKINLEYVILLE
COMMUNITY SERVICES DISTRICT AMENDING THE RULES AND
REGULATIONS TO REQUIRE SEWER BACKFLOW PREVENTION DEVICES OF
LATERALS AND CLARIFY MULTI-UNIT METER WATER CHARGES**

WHEREAS, MCSD currently has established rules on sewer lateral installation methods and has established rates for multi-unit water charges off one meter; and

WHEREAS, MCSD wishes to protect the District from unnecessary liability and prevent property damage to private property; and

WHEREAS, the District has been requested by the State Weights and Measures Department to clarify our water multi-unit charge verbiage.

NOW, THEREFORE, BE IT RESOLVED: that the Board of Directors of the McKinleyville Community Services District finds that in all buildings in which the floor level is below the elevation of the nearest manhole located upstream from the point at which the lateral sewer intersects the main, a backflow prevention device shall be installed in the building sewer at the expense of the owner.

BE IT FURTHER RESOLVED: that the Board of Directors clarifies the multi-unit water meter language, submitted as Exhibit III, to comply with the request from the State Weights and Measures Department for the benefit of our customers and the State Regulators.

PASSED AND ADOPTED at a duly called meeting of the Board of Directors of the McKinleyville Community Services District on the 16th day of August 16, 2006, by the following vote:

AYES: CORBETT, DUNK, REID, WENNERHOLM, TREPANIER

NOES: NONE

ABSENT: NONE

Attest: Sharon Denison
Sharon Denison, Secretary to the Board

Paul Trepanier
*Paul Trepanier, President of the
Board of Directors*